CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No.

3550-1739:100

Page 1 of 1

CATEGORY:

Door Closer/Holders/Releasing Devices

LISTEE:

CAL-ROYAL Products, Inc., 6605 Flotilla Street, City of Commerce, CA 90040

Contact: Kaye Yashar (323) 888-6601 Fax (323) 888-6699

kaye@cal-royal.com

DESIGN:

Models MDHR1 (Recessed wall mounted) and MDHS2 (Surface wall mounted)

electromagnetic door holders. Unit is a door holder, electromagnetic type, and direct pull, rated 30-45 lbs of holding force. Refer to listee's data sheet for additional detailed product

description and operational considerations.

RATING:

12/24 VAC/VDC and 24/120 VAC/VDC, Max. Holding Force: 30-45 lbs.

INSTALLATION:

In accordance with listee's printed installation instructions, applicable codes and ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING:

Listee's name, model number, electrical rating, load rating, and UL label.

APPROVAL:

Listed as electromagnetic door holders for use on fire-rated doors when installed in conjunction with separately listed smoke detection devices approved for releasing device

service. Authority having jurisdiction should be consulted prior to installation.

03-02-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MARCH 3, 2010

Listing Expires June 30, 2010

Authorized By:

FRANCIS MATEO, Program Coordinator

Fire Engineering Division